

## Annexure C

### PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. CHC/SDWSCC/April/2025/01 Dated: 11/07/2025

It is certified that an inspection team headed by DR. SACHIN KUMAR

(Name of Officers with designation) from Medical Superintendent PHED

inspected the Shri Advait Swaroop Global School, Mangli Azar, Sakoh'

(Name & Address of the school) on 11/07/2025 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. MRT/31 dated 07/07/2025

of District level water analysis lab (PHED Lab) certified that the

Shri Advait Swaroop Global School (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till one year

Signature with Seal: [Signature] चिकित्सा अधीक्षक

Name : सामु. स्वा. केन्द्र. दोसला (मेरठ)

Designation :

Name & Address of the Office / Department :

To Shri Advait Swaroop Global School

Mangli Azar, Sakoh', Meerut  
(Name & Address of the institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



**EXECUTIVE ENGINEER DIVISION OFFICE**  
**U.P. JAL NIGAM (RURAL),**  
**220, CIVIL LINES, MEERUT-250001**

E-mail: ee\_ist\_upjn\_mrt@yahoo.co.in

Letter :- 2599

/ पयल-41 / 44

Date :- 08/07/2025

**PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE**

It is certified that an inspection team headed by Vinay Kumar Nayak Junior Engineer Division office U.P Jal Nigam (Rural), Meerut inspected Shri Advait Swaroop Global School Nangli Aazar, Sakoti, Meerut on 05.07.2025 and on the basis of Water Test Report (Attached) Bearing No.MRT/31 Dated 07.07.2025 of District Level Water Analysis Laboratory UP Jal Nigam (Rural), Meerut Certified that the Shri Advait Swaroop Global School has safe drinking water facilities for the students and members of staff of the institution. As per the norms prescribed by the Central/State/U.T Govt.

The above valid for a period of 1 Year.

To,

Shri Advait Swaroop Global School,  
Nangli Aazar, Sakoti, Meerut

Singnature:.....

**Assistant Engineer**  
**Divisional Office**  
**U.P. Jal Nigam (Rural)**  
**Meerut**

Note:- The above certificate based on the sample test result.





# District Level Water Analysis Laboratory Uttar Pradesh Jal Nigam (Rural), Meerut

Issue No:04

Issue Date:  
17.10.2024

Revision No:00

## Test Report

Report Issue Date	07.07.2025		
URL	N/A		Date
Letter No.			04.07.2025
Customer Name and Address	SHRI ADVAIT SWAROOP GLOBAL SCHOOL, NANGLI AAZAR SAKOTI, MEERUT.		
Report No.	MRT/31		

Sampling Method ISO 17614 (Part - 1) : 2021

Sample Description:- Liquid transparent and colourless liquid received at ambient condition.

### Basic Details of Sample

District	MEERUT	Block	DAURALA
Gram Panchayat	NANGLI AAZAR	Village	NANGLI AAZAR
Habitation	NANGLI AAZAR	Location	SHRI ADVAIT SWAROOP GLOBAL SCHOOL, NANGLI AAZAR SAKOTI, MEERUT.
Water Source	TAP WATER	Sample ID	M/25/07/P31
Sample Collector	ABHISHEKH RATHI	Date of sampling.	05.07.2025
Depositor	ABHISHEKH RATHI	Receiving Date	05.07.2025
Discipline Sample	Chemical	Analysis Start Date	05.07. 2025
Packaging Type	Plastic bottle	Analysis Completion Date	07.07. 2025
Group	Water	Quantity	1 Liter
Temperature (25± 3)°C	27°C	Humidity (50%± 15%)	48%

### Technical Data of Analysis

SR. NO.	Analyzed parameters (Unit of Measurement)	Observed Value	Specified Values as per BIS		Ref. Method of Analysis
			Acceptable Limit	Permissible Limit	
1	2	3	4	5	6
1	pH @25°C	7.30	6.5-8.5	6.5-8.5	IS 3025 (Part 11): 2022 (Electrometric Method)
2	Turbidity (NTU)	1.50	1.00	5.00	IS 3025 (Part 10): 2023 (Nephelometer Method)
3	TDS. mg/l	208	500	2000	IS 3025 (Part 16): 2017(Gravimetric Method)
4	Chloride (as Cl), mg/l	22	250	1000	IS 3025 (Part 32): 2019(Titration Method)
5	Total Alkalinity (as Na <sub>2</sub> CO <sub>3</sub> ), mg/l	116	200	600	IS 3025 (Part 23): 2019(Titration Method)
6	Total Hardness (as CaCO <sub>3</sub> ), mg/l	124	200	600	IS 3025 (Part 21): 2019 (Titration Method)
7	Calcium (as Ca), mg/l	24	75	200	IS 3025 (Part 40): 2019
8	Magnesium (as Mg), mg/l	15.36	30	100	IS 3025 (Part 46): 2019
9	Sulphate (as SO <sub>4</sub> ), mg/l	-	200	400	APHA 23 <sup>RD</sup> Ed 2017, 4500-SO <sub>4</sub> (E. Turbidimetric Method)
10	Nitrate (as NO <sub>3</sub> ), mg/l	9.14	45	No Relaxation	APHA 23 <sup>RD</sup> Ed 2017, 4500-NO <sub>3</sub> (B. Ultraviolet Spectrophotometric Screening Method)
11	Fluoride (as F), mg/l	0.246	1.0	1.5	APHA 23 <sup>RD</sup> Ed 2017, 4500-F (C. Ion Selection Electrode Method)
12	Iron (as Fe), mg/l	0.05	1.0	No Relaxation	APHA 23 <sup>RD</sup> Ed 2017, 3500-Fe (B Phenanthroline Method)
13	Colour	5	5HU	15HU	APHA 23 <sup>RD</sup> Ed 2021 Colour Method (Platinum cobalt Visual Comparison):2017
14	Taste	Satisfactory	Qualitative	-	IS 3025 (Part 08): 2017
15	Odour	Satisfactory	Qualitative	-	IS 3025 ( Part 05): 2018
16	Conductivity	-	<2500	No rel.	Standard Value as per WHO (2017)
17	Free residual chlorine	0.1	0.2	1	IS 3025 (Part 26)
18	Total Coliform CFU/100 ml	ABSENT	No Relaxation	No Relaxation	APHA 23 Edition:2017
19	E.Coli CFU/100 ml	ABSENT	No Relaxation	No Relaxation	APHA 23 Edition:2017

#### Note:

1. Refers only to the particular sample(s) submitted for testing.
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
4. Sample will be stored up to 07 days (in case of non-perishable items only) from the date of issue of tests reports unless otherwise specified.
5. Water Sample is not collected by us.

  
Chemist  
Junior Engineer

.....End Of Report.....

  
Assistant Engineer  
Divisional Office  
U.P. Jal Nigam (Rural)  
Meerut